



# Puget Sound Clean Air Agency

Notice of  
Construction No. 8643

Registration No. 11339

Date

## HEREBY ISSUES AN ORDER OF APPROVAL TO CONSTRUCT, INSTALL, OR ESTABLISH

Two Pulse Jet Dust Collector Conversions (64 Filters @ 41.5"x6.13" each, @2.26 cfm/ft<sup>2</sup>) and Fans rated at 4200 CFM each to convert existing Sly Dust Collectors on Group II Cement Silos

### APPLICANT

Henrik Voldbaek  
Ash Grove Cement Company (E Marginal)  
3801 E Marginal Way S  
Seattle, WA 98134-1113

### OWNER

Ash Grove Cement Company (E Marginal)  
3801 E Marginal Way S  
Seattle, WA 98134-1113

### INSTALLATION ADDRESS

Ash Grove Cement Company (E Marginal), 3801 E Marginal Way S, Seattle, WA, 98134


### THIS ORDER IS ISSUED SUBJECT TO THE FOLLOWING RESTRICTIONS AND CONDITIONS

1. Approval is hereby granted as provided in Article 6 of Regulation I of the Puget Sound Clean Air Agency to the applicant to install or establish the equipment, device or process described hereon at the INSTALLATION ADDRESS in accordance with the plans and specifications on file in the Engineering Division of the Puget Sound Clean Air Agency.
2. This approval does not relieve the applicant or owner of any requirement of any other governmental agency.
3. The PM-10 emissions from these Two Pulse Jet Dust Collectors shall not exceed 0.005 grains/dscf over a 24-hour period. Ash Grove may demonstrate compliance with this condition by any of the following:
  - (a) By performing a Puget Sound Clean Air Agency-approved EPA Method 5 or EPA Method 201A;
  - (b) Demonstrating no visible emissions for 15 consecutive seconds;
  - (c) Demonstrating no visible emissions for 3 consecutive minutes; or
  - (d) Repairing within 24 hours, any baghouse that has visible emissions for more than 3 consecutive minutes.
4. Compliance shall be determined for visible emissions using 40 CFR 60 Method 22. Puget Sound Clean Air Agency may require a source test for any baghouse that has sustained visible emissions, unless such emissions are unavoidable under WAC 173-400-107.


### APPEAL RIGHTS

Pursuant to Puget Sound Clean Air Agency's Regulation I, Section 3.17 and RCW 43.21B.310, this Order may be appealed to the Pollution Control Hearings Board (PCHB). To appeal to the PCHB, a written notice of appeal must be filed with the PCHB and a copy served upon Puget Sound Clean Air Agency within 30 days of the date the applicant receives this Order.

# Order of Approval for NC No. 8643

  
Fredrick Austin  
P.E.  
Reviewing Engineer

ns

  
Steven Van Slyke  
Supervising Engineer